BUILDINGSAFETYCERTIFICATE

No.2024-25/1152

Dated: 24/02/2025

Certified that the existing buildings of Shri Dharmasthala Manjunatheshwara English Medium School, Ujire at Survey No. 518/1, Ujire Village, Belthangady Taluk, Dakshina Kannada District, Karnataka State -574240 comprised of one basement and one owned/occupied by Shri Dharmasthala Manjunatheshwara English Medium School, Ujire have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Public- Works Department (Name of Department/ Govt.) on14-02-2025(date of inspection) in the presence of Mr. Manmohan Naik G, Principal, Ujire Belthangady, Taluk Dakshina Kannada, District Karnataka State-574240 and that the building is fit for occupancy up to classes X with effect from 24/02/2025 in accordance with rule and subject to compliance of the specific conditions as appended.

- 1. Rebound Hammer Test: As per test conducted, Compressive strength of concrete column, Beams and Roof Slab for both Blocks-A & B falls in the range of 22N/Sq mm to 25N/Sq mm. as per table-2 of IS:516 (part-5/SEC4):2020
- 2. Ultrasonic Pulse Velocity Test: As per the Test Conducted, RC members fall in range of 3.5 to 4.00km/second, for both Blocks-a & B hence quality of concrete is graded as good as per table-1 of IS:516(Part-5/SEC1)3:2018.
- 3. Periodic maintenance of both Blocks-A & B building to be done regularly as mentioned below to keep the Building In good condition.
- 4. This Certificate is issued strictly subjected to rectify the observations made in the test report and Departmental observation at time of Visit and may be withdrawn if failed to comply.

Issued on 24/02/2025 at Belthangady by

Signature with Seal:

Name: Assistant Executive Engineer

Designation:

P.W.D Sub-division Beithangady

Name &Address of Department/Office:

(Assistant Engineer &above officer of concerned Govt. Department only)

NMOFFAMINGERIFICATE should be signed / issued by Assistant Engineer & above officer of concerned Govt.

Shri Dharmashala Manjunghesh

English Hering Spocertificate should be either in Hindi or English. If it is issued in vernacular language, 97 New School Code: 451 ansiated not acized version in English beuploaded along with the original vernacular certificate as a single pdf.

Dakshina Kannada Dist. - 574 240 Mobile: 94488 58058

Email:sdmemschool ujire@yahoo.co.in.